

HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT

No. PWN/CB/WA/Misc Building/2023-24/-1208-63 Dated:-07/02/2024
To

The Principal
Montessorie Cambriage School,
V.P.O. Raja Ka Bagh,
Tehsil Nurpur, Distt. Kangra (HP).

Subject: - Renewal of Building Safety Certificate for the session 2024-25.

With reference to your office letter No.Nil dated 06.02.2024, the building safety Certificate of your School is being sent for information and further action.

DA/As above.

(Signature)
Executive Engineer,
Nurpur Division, HP.PWD.
Nurpur.


Copy to the Assistant Engineer, Sub Division, HP.PWD.
Nurpur for information w.r.t. his office Letter No.1078 dated 07.02.2024

Executive Engineer,
Nurpur Division, HP.PWD.
Nurpur.

CERTIFICATE

The Inspection of School Building of The Montessorie Cambriage School, V.P.O. Raja Ka Bagh Tehsil. Nurpur, Distt. Kangra (HP) has been conducted by the Assistant Engineer, Sub Division, HP.PWD. Nurpur accompanied with Junior Engineer. On the basis of their inspection report, it has been found that no Earthquakes resistant norms have been adopted for the construction of School building.No structural drawings approved by the competent Govt. agency were produced by the school authority. The structure of the building is a non Engineering structure.Hence, the structural safety of building can't be ensured specially from Earthquake point of view. This Department will not responsible for any type of loss of life and property etc, if this structure fails under any circumstances.

However,as per visual inspection,the building appears to be safe and accordingly,the Building Safety Certificate is being issued by this Department from 1.4.2024 to 31.3.2025.ThisDepartment could not assess the structural safety of said building as the same was not constructed under the supervision of this Department.


Executive Engineer,
Nurpur Division, HP.PWD.
Nurpur.